



Status of Internal Parallel Run: Flow-based capacity calculation, pre-coupling

Nordic CCM Stakeholder Meeting
December 16, 2021

Jakob Glarbo Møller

jlm@energinet.dk



What is parallel run?

- The real market capacities are still based on NTC method (as today)
- The process for flow-based capacity allocation runs at the same time
- Goal:
 - Demonstrate stable process
 - Demonstrate adequate data quality
 - Assess impact on socio-economic welfare
 - Build experience with the new process and methodology

Internal parallel run

- Flow-based security domains are sent to SA WG to simulate market clearing and assess socio-economic welfare


External parallel run

- Flow-based security domains are sent to SA WG, NEMOs and external stakeholders (published through the Joint Allocation Office)



Flow-based IPR: High Level Process

IPR - Day ahead processes





IPR Statistics

- IPR started May 25 (5 days/week)
- Handover to NRSC Operation on October 12 (7 days/week)
- Domain validation by TSO operators gradually introduced since October 12
- Missing results for November 2 and 22 due to IT-failure

